

Scientific Air Solution



airPHX Companies
1311-A Dolley Madison Blvd.
McLean, VA 22101

November 24, 2019

Pre and In-Treatment Air and Surface Report – University [REDACTED] – Athletic Training

A. Summary – Air Samples

Pre and in-treatment air samples results given below.

Sample Date	Treatment	Number of samples	Location	Average (cfu/m ³)	Range	Standard Deviation	% Reduction
09/27/19	Pre	11	Various	427	267/633	104.3	-
11/08/19	In			39	0/100	39.7	90.9
09/27/19	Pre	2	Hallway	667	633/700	33.3	-
11/08/19	In			117	100/133	16.7	82.5
09/27/19	Pre	2	Hydro	483	400/567	83.3	-
11/08/19	In			467	400/533	66.7	3.4
09/27/19	Pre	2	Exterior	2,167	2,100/2,233	66.7	-
11/08/19	In			2,100	2,033/2,167	66.7	3.1

Background

All air samples were taken via the MB-1 air sampler, 30 liters per sample throughout the various locations given above with results normalized to colony forming units per cubic meter of air (cfu/m³).

Given below are airborne organisms found in the above locations for this **pre-treatment** sampling, excluding the outside samples.

Species	Raw Count	Species	Raw Count
<i>Penicillium, aspergillus types</i>	2,150	<i>Cladosporium sphaerospermum</i>	675
<i>Penicillium brevicompactum</i>	1,350	<i>Ulocladium chartarum</i>	525
<i>Aspergillus fumigatus</i>	895	<i>Absidia spp</i>	410
<i>Penicillium purpurogenum</i>	775	<i>Firmicutes spp</i>	220

Noted below are airborne organisms found in the above locations for this **in-treatment** sampling, excluding the outside samples.

Species	Raw Count	Species	Raw Count
<i>Penicillium, aspergillus types</i>	660	<i>Cladosporium sphaerospermum</i>	< 5
<i>Penicillium brevicompactum</i>	425	<i>Ulocladium chartarum</i>	< 5
<i>Aspergillus fumigatus</i>	390	<i>Absidia spp</i>	< 5
<i>Penicillium purpurogenum</i>	125	<i>Firmicutes spp</i>	< 5

09/27/19 - Pre-treatment bioburden in the above locations are > 300 cfu/m³ which is not acceptable and needs corrective action.

11/08/19 - In-treatment results show an **90.9% decrease** from the 09/27/19 pre-treatment samples and now are < 100 cfu/m³ which is considered **clean and acceptable**.

- The **Hallway** area which is out of the direct airPHX treatment area has seen the “halo effect” from the treatment area and is showing an **82.5% reduction** from the 09/27/19 pre-treatment samples.
- The **Hydro** area is further secluded and does see a **3.4% reduction** also seen as a slight “halo effect” from the treatment area.

Scientific Air Solution



Observations

The exterior air samples ranged from **2,033** to **2,233 cfu/m³** and reveals that most of the bioburden is attributed to the outside air. The airPHX unit is having a noticeable impact on reducing the bioburden.

Target Air Quality

Air quality scale for workplaces, public buildings, schools, and homes are as follows:

- < 100 cfu/m³ is considered **clean and acceptable**.
- 100 to 300 cfu/m³ is **marginal**.
- > 300 cfu/m³ is **not acceptable** and needs corrective action.

In most cases, air quality < **100 cfu/m³** has shown a decrease in the overall bioburden and odors.

Predominant Microorganisms

Although the predominant organisms noted in this report are fungi, previous testing results show bacteria, viruses and protozoa are eliminated as effectively as fungi. The reactive oxygen species (ROS) generated is effective on gram +, gram – bacteria, protozoa, spores and viruses.

B. Summary – Surface Contact Swabs

Pre and In-treatment surface (swab) samples results given below.

Sample Date	Treatment	Number of samples	Location	Average (cfu/cm ²)	Range	Standard Deviation	% Reduction
09/27/19	Pre	10	Various	56.2	29.0/125.0	33.0	-
11/08/19	In			1.8	0.8/4.5	1.3	96.8
09/27/19	Pre	1	Negative Control	0	0/0	-	-
11/08/19	In			0	0/0	-	-

09/27/19 - Pre-treatment contact swab results from the various locations are considerably > 5 cfu/cm² which is considered not acceptable and needs corrective action.

11/08/19 - In-treatment contact swab results reveal a **96.8% reduction** from the pre-treatment samples from the same locations which are now < 5 cfu/cm² and are considered **clean and acceptable**.

Target Contact Surface Quality


Contact surface quality scale for workplaces, public buildings, schools, and homes are as follows:

- < 5 cfu/cm² is considered **clean and acceptable**.
- 5 to 10 cfu/cm² is considered **marginal**.
- > 10 cfu/cm² is considered **not acceptable** and needs corrective action.

In most cases, surface swabs < **5 cfu/cm²** has shown a decrease in the overall bioburden and odors.

Please contact me if there are questions or if further information is needed.

Respectfully submitted,


Rick Falkenberg, Ph.D., CFS
Senior Principal Scientist

Scientific Air Solution



Table #1
University [REDACTED] – Athletic Training
11/08/19 In-treatment Air Sample Results - CFU/m³

In-treatment 11/08/2019 - [REDACTED] - Athletic Training						
Plate Lot No.	Air Sample Location	Air Sample Location	Liters of Air	Raw Count	Corrected Count	CFU/m ³
250	Ctrl	Unopened	0	0	0	0
249	1	ATR	30	2	2	67
248	2	ATR	30	3	3	100
187	3	ATR	30	2	2	67
191	4	ATR	30	3	3	100
247	5	ATR	30	0	0	0
195	6	ATR	30	0	0	0
246	7	ATR	30	2	2	67
254	8	ATR	30	0	0	0
253	9	ATR	30	0	0	0
252	10	ATR	30	0	0	0
240	11	ATR	30	1	1	33
243	12	Hallway	30	4	4	133
245	12A	Hallway	30	3	3	100
259	13	Hydro	30	12	12	400
258	14	Hydro	30	15	16	533
3241	1	Exterior	30	53	61	2,033
3235	2	Exterior	30	56	65	2,167

Avg 39 High 100

Low 0 SD 39.7

Avg 117 High 133

Low 100 SD 16.7

Avg 467 High 533

Low 400 SD 66.7

Avg 2,100 High 2,167

Low 2,033 SD 66.7

Total Adjusted Raw Count 20

Total CFU/m³ 1,600

Table #1, continued
University [REDACTED] – Athletic Training
09/27/19 Pre-treatment Air Sample Results - CFU/m³

Pre-treatment 09/27/2019 - [REDACTED] - Athletic Training						
Plate Lot No.	Air Sample Location	Air Sample Location	Liters of Air	Raw Count	Corrected Count	CFU/m ³
409	Ctrl	Unopened	0	0	0	0
405	1	ATR	30	10	10	333
401	2	ATR	30	12	12	400
397	3	ATR	30	16	17	567
393	4	ATR	30	12	12	400
389	5	ATR	30	13	13	433
385	6	ATR	30	12	12	400
381	7	ATR	30	10	10	333
377	8	ATR	30	8	8	267
3237	9	ATR	30	12	12	400
3238	10	ATR	30	18	19	633
3239	11	ATR	30	15	16	533
3240	12	Hallway	30	20	21	700
3236	12B	Hallway	30	18	19	633
373	13	Hydro	30	12	12	400
3234	14	Hydro	30	16	17	567
3241	1	Exterior	30	55	63	2,100
3235	2	Exterior	30	58	67	2,233

Avg 427 High 633

Low 267 SD 104.3

Avg 667 High 700

Low 633 SD 33.3

Avg 483 High 567

Low 400 SD 83.3

Avg 2,167 High 2,233

Low 2,100 SD 66.7

Total Adjusted Raw Count 181

Total CFU/m³ 7,000

Scientific Air Solution



Table #2

University [REDACTED] – Athletic Training
11/08/19 In-treatment Surface Sample Results – CFU/cm²

In-treatment 11/08/2019 - [REDACTED] - Athletic Training					
Room	Swab Number	Surface Swab Sample Location	10x10x10 cm	Raw Count	CFU/cm ²
N/A	CTRL	Swab not removed from container	0	0	0
Surface	1	End training rail	10x10x10	95	1.0
Surface	2	Rower back end	10x10x10	210	2.1
Surface	3	Dyantron face, station #8	10x10x10	100	1.0
Surface	4	Check-in counter	10x10x10	105	1.1
Surface	5	Hydro door handle/face of door	10x10x10	80	0.8
Surface	6	Floor leading into hydro room	10x10x10	100	1.0
Surface	7	Table in ortho room	10x10x10	310	3.1
Surface	8	Keyboard and handle in [REDACTED] office	10x10x10	450	4.5
			Avg	1.8	Max 4.5
			Min	0.8	SD 1.26

Total Adjusted Raw Count 1,450
Total CFU/cm² 15

Table #2, continued

University [REDACTED] – Athletic Training
09/27/19 Pre-treatment Surface Sample Results – CFU/cm²

Pre-treatment 09/27/2019 - [REDACTED] - Athletic Training					
Room	Swab Number	Surface Swab Sample Location	10x10x10 cm	Raw Count	CFU/cm ²
N/A	CTRL	Swab not removed from container	0	0	0
Surface	1	End training rail	10x10x10	3,500	35.0
Surface	2	Rower back end	10x10x10	7,500	75.0
Surface	3	Dyantron face, station #8	10x10x10	3,650	36.5
Surface	4	Check-in counter	10x10x10	3,410	34.1
Surface	5	Hydro door handle/face of door	10x10x10	2,900	29.0
Surface	6	Floor leading into hydro room	10x10x10	2,950	29.5
Surface	7	Table in ortho room	10x10x10	8,520	85.2
Surface	8	Keyboard and handle in [REDACTED] office	10x10x10	12,500	125.0
			Avg	56.2	Max 125.0
			Min	29.0	SD 32.99

Total Adjusted Raw Count 44,930
Total CFU/cm² 449



Table #3
University [REDACTED] – Athletic Training
11/08/2019- In-treatment Air Sample Pictures





Table #3, continued
University [REDACTED] – Athletic Training
09/27/2019 - Pre-treatment Air Sample Pictures



Scientific Air Solution



Table #4

University [REDACTED] – Athletic Training

11/08/19 and 09/27/2019 Pre and In-treatment Air and Surface Swab Locations

